



# PIR Ready VT7600 Series Programmable & Non-Programmable Thermostats For Commercial HVAC Applications

## LonWorks Integration Manual

(September 1, 2010)



## Product Overview

---

The VT7600 PI thermostat family is specifically designed for single stage and multi-stage control of heating/cooling equipment such as rooftop and self-contained units. The product features an intuitive, menu-driven, back-lit LCD display, which walks users through the programming steps, making the process extremely simple. Accurate temperature control is achieved due to the product's PI time proportional control algorithm, which virtually eliminates temperature offset associated with traditional, differential-based thermostats.

All models contain two digital inputs, which can be set by the user to monitor filter status, activate a remote temporary occupancy switch, and/or used as a general purpose service indicator. In addition, depending on the model, up to three remote sensor inputs are available. All models contain a SPST auxiliary switch, which can be used to control lighting or disable the economizer function and a discharge air sensor input. For more advanced applications, an economizer control logic has been integrated onto the thermostat for use with proportional damper economizer actuators.

The thermostats are also compatible with the new Vykon PIR cover accessories. Thermostats equipped with a PIR cover provide advanced active occupancy logic, which will automatically switch occupancy levels from Occupied to Unoccupied as required by local activity being present or not. This advanced occupancy functionality provides advantageous energy savings during occupied hours without sacrificing occupant comfort. All thermostats can be ordered with or without a factory installed PIR cover.

The additional following documentation is available :

- VYKONStat PIR Ready VT7600 Series Thermostat Installation Guide
- VYKONStat PIR Application Guide
- VYKONStat PIR Cover Assembly Installation Guide



## Contents

---

- PID History Revision Table
- Thermostat Objects
- SNVTs and SCPTs Table Per Model
- Input Network Variables (nvi's) Description
- Output Network Variables (nvo's) Description
- Configuration Properties (nci's) Description
- Integration - Global Commands
- Integration - Graphic User Interface (GUI) Objects
- Integration - Configuration Objects
- Wiring Guide
  - Overview
  - Network Configuration
  - Maximum Number Of Devices
  - Maximum Cable Length
  - Repeaters
  - Terminators
- Network Adapter
- External Interface File (XIF)
- Application Binary File (APB)
- Device Resource File (DRF)
- Plug-Ins File
- Device Identification
- Tips And Things You Need To Know
- Troubleshooting Section
- Document Control

## PID History Revision Table


**XIF, APB and NXE File Names and Corresponding PIDs.** This manual information is to be used only with the current released VT7600 PIR ready thermostats.

Used on current released thermostat	APB / NXE / XIF file names	Revision Level	Associated PID
PIR Ready VT7600 Series	VT76_PIR.XIF	Rev 3.0	80:00:C5:55:00:04:04:21

This manual information is **NOT** to be used only with the previously released VT7600 thermostats.

Previously released thermostat	APB / NXE / XIF file names	Revision Level	Associated PID
Non-RoHS VT7600 Series	VT7600.XIF	Rev 2.0 to 2.5	80:00:C5:55:00:04:04:02
RoHS VT7600 Series	VT7600r.XIF	Rev 2.0 to 2.5	80:00:C5:55:00:04:04:12
Non-RoHS T7600 Series	T7600.XIF	Rev 1.0	80:00:C5:55:00:04:04:0A

## Thermostat Objects



SNVTs<sup>1</sup> and SCPTs<sup>2</sup> Table Per Model

No	Sub	Point Name	Type	VT7656B5x28E	VT7605B5x28E	VT7652B5x28E	VT7600B5x28E	VT7652A5x28E	VT7600A5x28E	VT7652H5x28E	VT7600H5x28E
0		<b>nviSpaceTemp</b>	SNVT_temp_p	X	X	X	X	X	X	X	X
1		<b>nviOutdoorTemp</b>	SNVT_temp_p	X	X	X	X	X	X	X	X
2		<b>nviOccManCmd</b>	SNVT_occupancy	X	X	X	X	X	X	X	X
3		<b>nviApplicMode</b>	SNVT_hvac_mode	X	X	X	X	X	X	X	X
4		<b>nviSetpoint</b>	SNVT_temp_p	X	X	X	X	X	X	X	X
5		<b>nviTimeSet</b>	SNVT_time_stamp	X	N/A	X	N/A	X	N/A	X	N/A
6		<b>nciDaySched[0]</b>	UNVT_day_sched	X	N/A	X	N/A	X	N/A	X	N/A
7		<b>nciDaySched[1]</b>	UNVT_day_sched	X	N/A	X	N/A	X	N/A	X	N/A
8		<b>nciDaySched[2]</b>	UNVT_day_sched	X	N/A	X	N/A	X	N/A	X	N/A
9		<b>nciDaySched[3]</b>	UNVT_day_sched	X	N/A	X	N/A	X	N/A	X	N/A
10		<b>nciDaySched[4]</b>	UNVT_day_sched	X	N/A	X	N/A	X	N/A	X	N/A
11		<b>nciDaySched[5]</b>	UNVT_day_sched	X	N/A	X	N/A	X	N/A	X	N/A
12		<b>nciDaySched[6]</b>	UNVT_day_sched	X	N/A	X	N/A	X	N/A	X	N/A
13		<b>nciSetPts</b>	SNVT_temp_setpt	X	X	X	X	X	X	X	X
	1	occupied_cool		x	x	x	x	x	x	x	x
	3	unoccupied_cool		x	x	x	x	x	x	x	x
	4	occupied_heat		x	x	x	x	x	x	x	x
	6	unoccupied_heat		x	x	x	x	x	x	x	x
14		<b>nciCfg1RtuHp</b>	UNVT_cfg_1_rtu_hp	X	X	X	X	X	X	X	X
Associate with UNVT_cfg_1_rtu_hp format file											
	1	password	Unsigned-Long	x	x	x	x	x	x	x	x
	2	unoccupied_timer	Unsigned-Short	x	x	x	x	x	x	x	x
	3	anticycle	Unsigned-Short	x	x	x	x	x	x	x	x
	4	power_up_delay	Unsigned-Short	x	x	x	x	x	x	x	x
	5	temporary_occ_time	Unsigned-Short	x	x	x	x	x	x	x	x
	6	heating_stages_CPH	Unsigned-Short	x	x	x	x	x	x	x	x
	7	cooling_stages_CPH	Unsigned-Short	x	x	x	x	x	x	x	x
	8	heat_max_setpoint	SNVT_temp_p	x	x	x	x	x	x	x	x
	9	cool_min_setpoint	SNVT_temp_p	x	x	x	x	x	x	x	x
	10	OA_temp_heat_lockout	SNVT_temp_p	x	x	x	x	x	x	x	x
	11	OA_temp_cool_lockout	SNVT_temp_p	x	x	x	x	x	x	x	x
	12	calib_room_sensor	SNVT_temp_diff_p	x	x	x	x	x	x	x	x
	13	calib_outside_air_sensor	SNVT_temp_diff_p	x	x	x	x	x	x	x	x
	14	deadband	Unsigned-Short	x	x	x	x	x	x	x	x
	15	fan_mode	Enumeration Set Used: fan_mode_b-t	x	x	x	x	x	x	x	x
	16	fan_control	Enumeration Set Used: off_on_state_t	x	x	x	x	x	x	x	x
	17	fan_delay	Enumeration Set Used: off_on_state_t	x	x	x	x	x	x	x	x
	18	keypad_lockout	Enumeration Set Used: rem_lock_t	x	x	x	x	x	x	x	x
	19	proportional_band	Unsigned-Short	x	x	x	x	x	x	x	x
	20	temperature_units	Enumeration Set Used: temp_unit_t	x	x	x	x	x	x	x	x
	21	frost_protection	Enumeration Set Used: off_on_state_t	x	x	x	x	x	x	x	x
	22	menu_scroll	Enumeration Set Used: scroll_type_t	x	x	x	x	x	x	x	x

1: SNVTs: Standard Network Variables Types

2: SCPTs: Standard Configuration Parameters Types

No	Sub	Point Name	Type	VT7656B5x28E	VT7605B5x28E	VT7652B5x28E	VT7600B5x28E	VT7652A5x28E	VT7600A5x28E	VT7652H5x28E	VT7600H5x28E
15		<b>nciCfg2RtuHp</b>	UNVT_cfg_2_rtu_hp	X	X	X	X	N/A	N/A	X	X
Associate with UNVT_cfg_2_rtu_hp format file											
	1	di1_config	Enumeration Set Used: input_cfg_model_d_t	x	x	x	x	x	x	x	x
	2	di2_config	Enumeration Set Used: input_cfg_model_d_t	x	x	x	x	x	x	x	x
	3	aux_contact_config	Enumeration Set Used: aux_contact_cfg_t	x	x	x	x	x	x	x	x
	4	number_of_events	Enumeration Set Used: nb_of_events_t	x	N/A	x	N/A	x	N/A	x	N/A
	5	progresive_recovery	Enumeration Set Used: off_on_state_t	x	N/A	x	N/A	x	N/A	x	N/A
	6	a.hp_rev_valve_config	Enumeration Set Used: rev_valve_b_t	N/A	N/A	N/A	N/A	N/A	N/A	x	x
	7	a.number_of_heating_stages	Enumeration Set Used: nb_stages_t	x	x	x	x	N/A	N/A	N/A	N/A
	8	number_of_cool_or_hp_stages	Enumeration Set Used: nb_stages_t	x	x	x	x	N/A	N/A	x	x
	9	econo_min_position	SNVT_lev_percent	x	x	N/A	N/A	N/A	N/A	N/A	N/A
	10	b.hp_high_balance_point	SNVT_temp_p	N/A	N/A	N/A	N/A	N/A	N/A	x	X
	11	b.econo_changeover_setpoint	SNVT_temp_p	x	x	N/A	N/A	N/A	N/A	N/A	N/A
	12	c.hp_low_balance_point	SNVT_temp_p	N/A	N/A	N/A	N/A	N/A	N/A	x	x
	13	c.econo_mixed_air_setpoint	SNVT_temp_p	x	x	N/A	N/A	N/A	N/A	N/A	N/A
	14	d.hp_comfort_or_economy_mode	Enumeration Set Used: mode_t	N/A	N/A	N/A	N/A	N/A	N/A	x	x
	15	d.econo_mechanical_cool_enable	Enumeration Set Used: off_on_state_t	x	x	N/A	N/A	N/A	N/A	N/A	N/A
	16	hp_compressor_auxheat_interlock	Enumeration Set Used: off_on_state_t	N/A	N/A	N/A	N/A	N/A	N/A	x	x
16		<b>nciHvacType</b>	SNVT_hvac_type	X	X	X	X	X	X	X	X
17		<b>nciSccModel</b>	UNVT_model_numbe	X	X	X	X	X	X	X	X
	1	Thermostat Model		x	x	x	x	x	x	x	x
	2	Software Version		x	x	x	x	x	x	x	x
18		<b>nvoSpaceTemp</b>	SNVT_temp_p	X	X	X	X	X	X	X	X
19		<b>nvoUnitStatus</b>	SNVT_hvac_status	X	X	X	X	X	X	X	X
	1	mode		x	x	x	x	x	x	x	x
	2	heat_output_primary		x	x	x	x	x	x	x	x
	3	heat_output_secondary		N/A	N/A	N/A	N/A	N/A	N/A	x	x
	4	cool_output		x	x	x	x	x	x	x	x
	5	econo_output		x	x	N/A	N/A	N/A	N/A	N/A	N/A
	6	Fan_output		x	x	x	x	x	x	x	x
	7	in_alarm		x	x	x	x	x	x	x	x
20		<b>nvoOutdoorTemp</b>	SNVT_temp_p	X	X	X	X	X	X	X	X
21		<b>nvoDischAirTemp</b>	SNVT_temp_p	X	X	X	X	X	X	X	X
22		<b>nvoEffectOccup</b>	SNVT_occupancy	X	X	X	X	X	X	X	X

No	Sub	Point Name	Type	VT7656B5x28E	VT7605B5x28E	VT7652B5x28E	VT7600B5x28E	VT7652A5x28E	VT7600A5x28E	VT7652H5x28E	VT7600H5x28E
23		<b>nvoSccStatus</b>	UNVT_thermo_state_rtu UNVT_thermo_state_hp	X	X	X	X	X	X	X	X
For all non heatpump models, associate with UNVT_thermo_state_rtu											
	1	fan_output	True bit index 2	x	x	x	x	x	x	x	x
	2	cooling_stage_1	True bit index 3	x	x	x	x	x	x	x	x
	3	cooling_stage_2	True bit index 4	x	x	x	x	N/A	N/A	x	x
	4	auxiliary_contact	True bit index 5	x	x	x	x	x	x	x	x
	5	heating_stage_1	True bit index 6	x	x	x	x	x	x	x	x
	6	heating_stage_2	True bit index 7	x	x	x	x	x	x	x	x
	7	service_alarm	True bit index 12	x	x	x	x	x	x	x	x
	8	filter_alarm	True bit index 13	x	x	x	x	x	x	x	x
	9	di2_direct_status	True bit index 17	x	x	x	x	x	x	x	x
	10	di1_direct_status	True bit index 18	x	x	x	x	x	x	x	x
	11	set_clock_alarm	True bit index 22	x	N/A	x	N/A	x	N/A	x	N/A
	12	frost_protection_alarm	True bit index 23	x	x	x	x	x	x	x	x
	13	local_pir_motion	True bit index 24	x	x	x	x	x	x	x	x
	14	fan_lock_alarm	True bit index 25								
For all heatpump models, associate with UNVT_thermo_state_hp											
	1	fan_output	True bit index 2	x	x	x	x	x	x	x	x
	2	compressor_stage_1	True bit index 3	x	x	x	x	x	x	x	x
	3	compressor_stage_2	True bit index 4	x	x	x	x	N/A	N/A	x	x
	4	auxiliary_contact	True bit index 5	x	x	x	x	x	x	x	x
	5	heating_stage_1	True bit index 6	x	x	x	x	x	x	x	x
	6	reversing_valve	True bit index 7	x	x	x	x	x	x	x	x
	7	service_alarm	True bit index 12	x	x	x	x	x	x	x	x
	8	filter_alarm	True bit index 13	x	x	x	x	x	x	x	x
	9	di2_direct_status	True bit index 17	x	x	x	x	x	x	x	x
	10	di1_direct_status	True bit index 18	x	x	x	x	x	x	x	x
	11	set_clock_alarm	True bit index 22	x	N/A	x	N/A	x	N/A	x	N/A
	12	frost_protection_alarm	True bit index 23	x	x	x	x	x	x	x	x
	13	local_pir_motion	True bit index 24	x	x	x	x	x	x	x	x
	14	fan_lock_alarm	True bit index 25								
24		<b>nvoEffectSetpt</b>	SNVT_temp_p	X	X	X	X	X	X	X	X
25		<b>nvoSetpoint</b>	SNVT_temp_p	X	X	X	X	X	X	X	X
26		<b>nciSndHrtBt</b>	SNVT_time_sec	X	X	X	X	X	X	X	X
27		<b>nciMinOutTm</b>	SNVT_time_sec	X	X	X	X	X	X	X	X
28		<b>nciRcvHrtBt</b>	SNVT_time_sec	X	X	X	X	X	X	X	X
29		<b>nciMajVer</b>	SCPT_maj_ver	X	X	X	X	X	X	X	X
30		<b>nciMinVer</b>	SCPT_min_ver	X	X	X	X	X	X	X	X
31		<b>nciLocation</b>	SNVT_str_asc	X	X	X	X	X	X	X	X

## Input Network Variables (nvi's) Description

Parameter	Variable Name	Function
Room Temperature	network input SNVT_temp_p <b>nviSpaceTemp</b>	<ul style="list-style-type: none"> <li>➤ This input network variable provides a network remote temperature value to the thermostat. If a valid value is present, the internal temperature reading (internal sensor) is no longer used.</li> <li>➤ Valid Range: -40 to 122°F (-40 to 50°C)</li> <li>➤ Default Null (release) Value: 621.81°F (327.67°C or 0x7FFF)</li> <li>➤ This network variable is subject to the Receive HeartBeat Time, nviRcvHrtBt.</li> </ul>
Outdoor Air Temperature	network input SNVT_temp_p <b>nviOutdoorTemp</b>	<ul style="list-style-type: none"> <li>➤ This input network variable provides outdoor air temperature information to the thermostat from a network value temperature value. If a valid value is present, the internal temperature reading (internal sensor) is no longer used. The device will automatically display the value on its display when used.</li> <li>➤ Valid Range: -40 to 122°F (-40 to 50°C)</li> <li>➤ Default Null (release) Value: 621.81°F (327.67°C or 0x7FFF)</li> </ul>
Occupancy	network input SNVT_occupancy <b>nviOccManCmd</b>	<ul style="list-style-type: none"> <li>➤ This input network variable is used to command the Space Comfort Controller into different occupancy modes. It is typically set by a supervisory node to manually control occupancy modes, or to override the scheduled occupancy.</li> <li>➤ Default Null Value: OC_NUL = 0xFF</li> <li>➤ Valid Range: <ul style="list-style-type: none"> <li>0 = OC_OCCUPIED</li> <li>1 = OC_UNOCCUPIED</li> <li>2 = OC_BYPASS – <b>Not Used</b></li> <li>3 = OC_STANDY – <b>Not Used</b></li> <li>0xFF = OC_NUL (Release to internal occupancy)**</li> </ul> </li> </ul> <p>* OC_OCCUPIED and OC_UNOCCUPIED commands will always have full authority over the local occupancy routines of the thermostat may they be a local input or a PIR cover.</p> <p>** OC_NUL command will release the thermostat to use its own internal occupancy routine driven by the local schedule, one of the digital input or a PIR cover installed on board.</p>
System Mode	network input SNVT_hvac_mode <b>nviApplicMode</b>	<ul style="list-style-type: none"> <li>➤ This network variable input is used to coordinate the Space Comfort Controller with any node that may need to control the heat/cool changeover of the unit.</li> <li>➤ Default Null Value: HVAC_AUTO.</li> <li>➤ This network variable is subject to the receive heartbeat time, nciRcvHrtBt</li> <li>➤ Valid Range: <ul style="list-style-type: none"> <li>0 = HVAC_AUTO</li> <li>1 = HVAC_HEAT</li> <li>2 = HVAC_MRNG_WRMUP – <b>Not Used</b></li> <li>3 = HVAC_COOL</li> <li>4 = HVAC_NIGHT_PURGE – <b>Not Used</b></li> <li>5 = HVAC_PRE_COOL – <b>Not Used</b></li> <li>6 = HVAC_OFF</li> <li>7 = HVAC_TEST – <b>Not Used</b></li> <li>8 = HVAC_EMERG_HEAT – <b>Not Used</b></li> <li>9 = HVAC_FAN_ONLY – <b>Not Used</b></li> <li>12 = HVAC_MAX_HEAT – <b>Not Used</b></li> <li>13 = HVAC_ECONOMY – <b>Not Used</b></li> <li>14 = HVAC_DEHUMID – <b>Not Used</b></li> <li>15 = HVAC_CALIBRATE – <b>Not Used</b></li> <li>0xFF = HVAC_NUL – <b>Not Used</b></li> </ul> </li> </ul>

Parameter	Variable Name	Function																												
Occupied Cool & Heat Setpoints	network Input SNVT_temp_p <b>nviSetpoint</b>	<ul style="list-style-type: none"> <li>➤ This input network variable is used to allow the occupied temperature setpoints only to be changed via the network from a single analog value. (Note: the Unoccupied setpoints are not changed). The corresponding heating and cooling values are derived from the minimum deadband configuration value</li> <li>➤ Default Null Value: 621.81°F (327.67°C or 0x7FFF)</li> <li>➤ Ex. If the minimum deadband configuration value = 2 °F and nviSetpoint = 70°F. <ul style="list-style-type: none"> <li>• The resulting Occupied heating setpoint will equal 69 °F which is derived from 70 °F minus ½ the minimum deadband configuration value of 2 °F</li> <li>The resulting Occupied cooling setpoint will equal 71 °F which is derived from 70 °F plus ½ the minimum deadband configuration value of 2 °F</li> </ul> </li> </ul>																												
Date and time	network input SNVT_time_stamp <b>nviTimeSet</b>	<ul style="list-style-type: none"> <li>➤ This input network variable is used to set the time and date of the Space Comfort Controller.</li> <li>➤ Default Null Value :</li> </ul> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Sub</th> <th>Name</th> <th>Valid Range</th> <th>Default Value</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>year</td> <td>0 to 3000</td> <td>0</td> </tr> <tr> <td>2</td> <td>month</td> <td>0 to 12</td> <td>0</td> </tr> <tr> <td>3</td> <td>day</td> <td>0 to 31</td> <td>0</td> </tr> <tr> <td>4</td> <td>hour</td> <td>0 to 23</td> <td>0</td> </tr> <tr> <td>5</td> <td>minute</td> <td>0 to 59</td> <td>0</td> </tr> <tr> <td>6</td> <td>second</td> <td>0 to 59</td> <td>0</td> </tr> </tbody> </table>	Sub	Name	Valid Range	Default Value	1	year	0 to 3000	0	2	month	0 to 12	0	3	day	0 to 31	0	4	hour	0 to 23	0	5	minute	0 to 59	0	6	second	0 to 59	0
Sub	Name	Valid Range	Default Value																											
1	year	0 to 3000	0																											
2	month	0 to 12	0																											
3	day	0 to 31	0																											
4	hour	0 to 23	0																											
5	minute	0 to 59	0																											
6	second	0 to 59	0																											



## Output Network Variables (nvo's) Description

All output network variables will be updated no faster than the Minimum Send Time (nciMinOutTm) configuration value, if used.

An output network variable will be transmitted immediately when its value has changed significantly. Additionally, this variable will also be transmitted as a heartbeat output on a regular basis as dictated by the Maximum Send Time (nciSndHrtBt) configuration value.

Parameter	Variable Name	Function																								
Room Temperature	network output SNVT_temp_p <b>nvoSpaceTemp</b>	<ul style="list-style-type: none"> <li>➤ This output network variable is used to monitor the effective space temperature sensor that the Space Comfort Controller is using for control. This output echoes the value of the input.</li> <li>➤ Valid Range: -40 to 122°F (-40 to 50°C)</li> <li>➤ The value 621.07°F (327.67°C or 0x7FFF) will be sent as an invalid value in case of a sensor failure.</li> </ul>																								
Unit Status	network output SNVT_hvac_status <b>nvoUnitStatus</b>	<ul style="list-style-type: none"> <li>➤ This output network variable is available to report the Space Comfort Controller status. It combines the operating mode, the capacity of heating and cooling used and an indication if any alarms are present in the object.</li> </ul> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Sub</th> <th>Name</th> <th>Valid Value</th> </tr> </thead> <tbody> <tr> <td>01</td> <td>mode</td> <td>HVAC_HEAT HVAC_MRNG_WRMUP – <b>Not Used</b> HVAC_COOL HVAC_NIGHT_PURGE – <b>Not Used</b> HVAC_PRE_COOL – <b>Not Used</b> HVAC_HVAC_OFF HVAC_HVAC_TEST – <b>Not Used</b> HVAC_HVAC_EMERG_HEAT – <b>Not Used</b> HVAC_FAN_ONLY – <b>Not Used</b> HVAC_MAX_HEAT – <b>Not Used</b></td> </tr> <tr> <td>02:</td> <td>heat_output_primary</td> <td>0-100%</td> </tr> <tr> <td>03</td> <td>heat_output_secondary</td> <td>0-100%</td> </tr> <tr> <td>04</td> <td>cool_output:</td> <td>0-100%</td> </tr> <tr> <td>05</td> <td>econ_output</td> <td>0-100%</td> </tr> <tr> <td>06</td> <td>fan_output</td> <td>0-100%</td> </tr> <tr> <td>07</td> <td>In_alarm</td> <td>0 (No alarms) 1 (Alarm On) 0x7FF (Alarming disabled) – <b>Not Used</b></td> </tr> </tbody> </table>	Sub	Name	Valid Value	01	mode	HVAC_HEAT HVAC_MRNG_WRMUP – <b>Not Used</b> HVAC_COOL HVAC_NIGHT_PURGE – <b>Not Used</b> HVAC_PRE_COOL – <b>Not Used</b> HVAC_HVAC_OFF HVAC_HVAC_TEST – <b>Not Used</b> HVAC_HVAC_EMERG_HEAT – <b>Not Used</b> HVAC_FAN_ONLY – <b>Not Used</b> HVAC_MAX_HEAT – <b>Not Used</b>	02:	heat_output_primary	0-100%	03	heat_output_secondary	0-100%	04	cool_output:	0-100%	05	econ_output	0-100%	06	fan_output	0-100%	07	In_alarm	0 (No alarms) 1 (Alarm On) 0x7FF (Alarming disabled) – <b>Not Used</b>
Sub	Name	Valid Value																								
01	mode	HVAC_HEAT HVAC_MRNG_WRMUP – <b>Not Used</b> HVAC_COOL HVAC_NIGHT_PURGE – <b>Not Used</b> HVAC_PRE_COOL – <b>Not Used</b> HVAC_HVAC_OFF HVAC_HVAC_TEST – <b>Not Used</b> HVAC_HVAC_EMERG_HEAT – <b>Not Used</b> HVAC_FAN_ONLY – <b>Not Used</b> HVAC_MAX_HEAT – <b>Not Used</b>																								
02:	heat_output_primary	0-100%																								
03	heat_output_secondary	0-100%																								
04	cool_output:	0-100%																								
05	econ_output	0-100%																								
06	fan_output	0-100%																								
07	In_alarm	0 (No alarms) 1 (Alarm On) 0x7FF (Alarming disabled) – <b>Not Used</b>																								
Outdoor Temperature	network output SNVT_temp_p <b>nvoOutdoorTemp</b>	<ul style="list-style-type: none"> <li>➤ This output network variable is used to monitor the outdoor air temperature.</li> <li>➤ Valid Range: -40 to 122°F (-40 to 50°C)</li> <li>➤ The value 621.07°F (327.67°C or 0x7FFF) will be sent as an invalid value in case of a sensor failure or if unconnected.</li> </ul>																								

Parameter	Variable Name	Function																																																												
Supply Temperature	network output SNVT_temp_p <b>nvoDischAirTemp</b>	<ul style="list-style-type: none"> <li>➤ This output network variable is used to monitor the temperature of the air that leaves the Space Comfort Controller</li> <li>➤ Valid Range: -40 to 122°F (-40 to 50°C)</li> <li>➤ The value 621.81°F (327.67°C or 0x7FFF) will be sent as an invalid value in case of a sensor failure.</li> </ul>																																																												
Occupancy	network output SNVT_occupancy <b>nvoEffectOccup</b>	<ul style="list-style-type: none"> <li>➤ This output network variable is used to indicate the actual occupancy mode of the unit. This information is typically reported to a supervisory controller or provided to another Space Comfort Controller to coordinate the operation of multiple units</li> <li>➤ Valid Range: <ul style="list-style-type: none"> <li>0 = OC_OCCUPIED</li> <li>1 = OC_UNOCCUPIED</li> <li>2 = OC_BYPASS<sup>1</sup></li> <li>3 = OC_STANDBY – <b>Not Used</b></li> </ul> </li> </ul> <p><b>NOTE</b> : OC_BYPASS can be initiated by either nviOccManCmd or a local input. NvoEffectOccup will only be in OC_BYPASS for the duration of the ToccTime (nciGenOpts), until reinitiated by either a transition of the local input or an update to nviOccManCmd.</p>																																																												
Thermostat's I/O status	network output UNVT_thermo_state_rtu UNVT_thermo_state_hp  <b>nvoSccStatus</b>	<ul style="list-style-type: none"> <li>➤ This network variable output is used to report the Space Comfort Controller inputs' and outputs' status.</li> </ul>																																																												
		<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 5%;">Sub</th> <th style="width: 55%;">Name</th> <th style="width: 20%;">Valid value</th> <th style="width: 20%;">True bit index</th> </tr> </thead> <tbody> <tr> <td></td> <td>fan output</td> <td>0 = Off 1 = On</td> <td>2</td> </tr> <tr> <td></td> <td>cooling stage 1 compressor stage 1</td> <td>0 = Off 1 = On</td> <td>3</td> </tr> <tr> <td></td> <td>cooling stage 2 compressor stage 2</td> <td>0 = Off 1 = On</td> <td>4</td> </tr> <tr> <td></td> <td>auxiliary contact</td> <td>0 = Off 1 = On</td> <td>5</td> </tr> <tr> <td></td> <td>heating stage 1</td> <td>0 = Off 1 = On</td> <td>6</td> </tr> <tr> <td></td> <td>heating stage 2 reversing valve</td> <td>0 = Off 1 = On</td> <td>7</td> </tr> <tr> <td></td> <td>service alarm</td> <td>0 = Off 1 = On</td> <td>12</td> </tr> <tr> <td></td> <td>filter alarm</td> <td>0 = Off 1 = On</td> <td>13</td> </tr> <tr> <td></td> <td>di2 direct status</td> <td>0 = Activated 1 = Not Activated</td> <td>17</td> </tr> <tr> <td></td> <td>di1 direct status</td> <td>0 = Activated 1 = Not Activated</td> <td>18</td> </tr> <tr> <td></td> <td>set clock alarm</td> <td>0 = Off 1 = On</td> <td>22</td> </tr> <tr> <td></td> <td>frost protection alarm</td> <td>0 = Off 1 = On</td> <td>23</td> </tr> <tr> <td></td> <td>local pir motion</td> <td>0 = Off 1 = On</td> <td>24</td> </tr> <tr> <td></td> <td>fan lock alarm</td> <td>0 = Off 1 = On</td> <td>25</td> </tr> </tbody> </table>	Sub	Name	Valid value	True bit index		fan output	0 = Off 1 = On	2		cooling stage 1 compressor stage 1	0 = Off 1 = On	3		cooling stage 2 compressor stage 2	0 = Off 1 = On	4		auxiliary contact	0 = Off 1 = On	5		heating stage 1	0 = Off 1 = On	6		heating stage 2 reversing valve	0 = Off 1 = On	7		service alarm	0 = Off 1 = On	12		filter alarm	0 = Off 1 = On	13		di2 direct status	0 = Activated 1 = Not Activated	17		di1 direct status	0 = Activated 1 = Not Activated	18		set clock alarm	0 = Off 1 = On	22		frost protection alarm	0 = Off 1 = On	23		local pir motion	0 = Off 1 = On	24		fan lock alarm	0 = Off 1 = On	25
		Sub	Name	Valid value	True bit index																																																									
			fan output	0 = Off 1 = On	2																																																									
			cooling stage 1 compressor stage 1	0 = Off 1 = On	3																																																									
			cooling stage 2 compressor stage 2	0 = Off 1 = On	4																																																									
			auxiliary contact	0 = Off 1 = On	5																																																									
			heating stage 1	0 = Off 1 = On	6																																																									
			heating stage 2 reversing valve	0 = Off 1 = On	7																																																									
			service alarm	0 = Off 1 = On	12																																																									
			filter alarm	0 = Off 1 = On	13																																																									
			di2 direct status	0 = Activated 1 = Not Activated	17																																																									
			di1 direct status	0 = Activated 1 = Not Activated	18																																																									
			set clock alarm	0 = Off 1 = On	22																																																									
	frost protection alarm	0 = Off 1 = On	23																																																											
	local pir motion	0 = Off 1 = On	24																																																											
	fan lock alarm	0 = Off 1 = On	25																																																											

Parameter	Variable Name	Function
Setpoint	network output SNVT_temp_p <b>nvoEffectSetpt</b>	<ul style="list-style-type: none"> <li>➤ This output network variable is used to monitor the effective temperature setpoint which may depend on nciSetpoints, nvoEffectOccup, nviSetpoint and any local setpoint adjustment. For example, if the occupancy state is unoccupied and the heat/cool state is heat, the effective setpoint would be equal to the unoccupied heating setpoint defined in nciSetpoints.</li> <li>➤ Valid Range: -40 to 100°F (-40 to 37.5°C)</li> </ul>
Local setpoint output	network output SNVT_temp_p <b>nvoSetPoint</b>	<ul style="list-style-type: none"> <li>➤ This output network variable is used to monitor the space temperature setpoint</li> <li>➤ Valid Range : 40°F to 100°F (4.5°C to 37.5°C)</li> <li>➤ The present value is derived by the following OccHeat Setpoint + ((OccCool Setpoint – OccHeat Setpoint) / 2)</li> </ul>

### Configuration properties (nci's) Description

Parameter	Variable Name	Function																												
Schedule	network input config UNVT_day_sched <b>nciDay_Sched[x]</b> x = 0 to 6	<ul style="list-style-type: none"> <li>➤ This configuration property defines the schedule for every day of the week (from Monday to Sunday or from day 0 to day 6). This nci is linked with the nvoEffectOccup variable.</li> <li>➤ 2 or 4 events can entered depending on the nb_of_events variable.</li> <li>➤ Starting and ending time are entered in minutes, e.i. 11:59 pm is equal to 1439 minutes (23 hours * 60 min + 59 min)</li> <li>➤ Valid Range : 0 to 1439 minutes</li> <li>➤ Default values:</li> </ul> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Sub</th> <th>Name</th> <th>Default Value</th> </tr> </thead> <tbody> <tr> <td>1</td> <td>occupied_event_1</td> <td>0</td> </tr> <tr> <td>2</td> <td>unoccupied_event_2</td> <td>1439</td> </tr> <tr> <td>3</td> <td>occupied_event_3</td> <td>0</td> </tr> <tr> <td>4</td> <td>unoccupied_event_4</td> <td>1439</td> </tr> </tbody> </table>	Sub	Name	Default Value	1	occupied_event_1	0	2	unoccupied_event_2	1439	3	occupied_event_3	0	4	unoccupied_event_4	1439													
Sub	Name	Default Value																												
1	occupied_event_1	0																												
2	unoccupied_event_2	1439																												
3	occupied_event_3	0																												
4	unoccupied_event_4	1439																												
Temperature Setpoints	network input config SNVT_temp_setpt <b>nciSetPts</b>	<ul style="list-style-type: none"> <li>➤ This configuration property defines the space temperature setpoints for various heat, cool and occupancy modes.</li> <li>➤ The stand-by setpoints can be modified but are not used by the controller, as it does not support Stand-By occupancy mode.</li> <li>➤ Valid Range and Default values:</li> </ul> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Sub</th> <th>Name</th> <th>Valid Range</th> <th>Default value</th> </tr> </thead> <tbody> <tr> <td>01</td> <td>occupied_cool</td> <td>54 to 100°F (12 to 37.5°C)</td> <td>73.5°F (23°C)</td> </tr> <tr> <td>02</td> <td>standby_cool</td> <td><b>Not Used</b></td> <td><b>Not Used</b></td> </tr> <tr> <td>03</td> <td>unoccupied_cool</td> <td>54 to 100°F (12 to 37.5°C)</td> <td>82.5°F (28°C)</td> </tr> <tr> <td>04</td> <td>occupied_heat</td> <td>40 to 90°F (4.5 to 32°C)</td> <td>70°F (21°C)</td> </tr> <tr> <td>05</td> <td>standby_heat</td> <td><b>Not Used</b></td> <td><b>Not Used</b></td> </tr> <tr> <td>06</td> <td>unoccupied_heat</td> <td>40 to 90°F (4.5 to 32°C)</td> <td>61°F (16°C)</td> </tr> </tbody> </table>	Sub	Name	Valid Range	Default value	01	occupied_cool	54 to 100°F (12 to 37.5°C)	73.5°F (23°C)	02	standby_cool	<b>Not Used</b>	<b>Not Used</b>	03	unoccupied_cool	54 to 100°F (12 to 37.5°C)	82.5°F (28°C)	04	occupied_heat	40 to 90°F (4.5 to 32°C)	70°F (21°C)	05	standby_heat	<b>Not Used</b>	<b>Not Used</b>	06	unoccupied_heat	40 to 90°F (4.5 to 32°C)	61°F (16°C)
Sub	Name	Valid Range	Default value																											
01	occupied_cool	54 to 100°F (12 to 37.5°C)	73.5°F (23°C)																											
02	standby_cool	<b>Not Used</b>	<b>Not Used</b>																											
03	unoccupied_cool	54 to 100°F (12 to 37.5°C)	82.5°F (28°C)																											
04	occupied_heat	40 to 90°F (4.5 to 32°C)	70°F (21°C)																											
05	standby_heat	<b>Not Used</b>	<b>Not Used</b>																											
06	unoccupied_heat	40 to 90°F (4.5 to 32°C)	61°F (16°C)																											

Parameter	Variable Name	Function																																																																					
Thermostat's common configuration parameters network input config	UNVT_cfg_1_rtu_hp <b>nciCfg1RtuHpt</b>	<ul style="list-style-type: none"> <li>➤ This configuration property defines the thermostat's common configuration parameters and their settings.</li> <li>➤ Valid Range and Default values:</li> </ul>																																																																					
		<table border="1"> <thead> <tr> <th>Name</th> <th>Valid Range</th> <th>Default value</th> </tr> </thead> <tbody> <tr> <td>password</td> <td>0 to 1000</td> <td>0</td> </tr> <tr> <td>unoccupied timer</td> <td>0.5 to 24.0 hours</td> <td>0.5</td> </tr> <tr> <td>anticycle</td> <td>0, 1, 2, 3, 4, or 5 minutes</td> <td>2 minutes</td> </tr> <tr> <td>power-up delay</td> <td>10 to 120 sec.</td> <td>10 sec.</td> </tr> <tr> <td>temporary occ time</td> <td>0, 1, 2, 3 to 12 hours</td> <td>3 hours</td> </tr> <tr> <td>heating stages cph</td> <td>3, 4, 5, 6, 7 or 8 CPH</td> <td>4 CPH</td> </tr> <tr> <td>cooling stages cph</td> <td>3 or 4 CPH</td> <td>4 CPH</td> </tr> <tr> <td>heat maximum setpoint</td> <td>40 to 90°F (4.5 to 32°C)</td> <td>90°F</td> </tr> <tr> <td>cool minimum setpoint</td> <td>54 to 100°F (12 to 37.5°C)</td> <td>54°F</td> </tr> <tr> <td>oa temp heat lockout</td> <td>-15 to 120°F (-26 to 49°C)</td> <td>120°F</td> </tr> <tr> <td>oa temp cool lockout</td> <td>-40 to 95°F (-40 to 35°C)</td> <td>-40°F</td> </tr> <tr> <td>calib room sensor</td> <td>±5°F (±2.5°C)</td> <td>0°F</td> </tr> <tr> <td>calib outdoor air sensor</td> <td>±5°F (±2.5°C)</td> <td>0°F</td> </tr> <tr> <td>deadband</td> <td>2 to 4°F with 1°F increments (1 to 2°C)</td> <td>2°F</td> </tr> <tr> <td>fan mode</td> <td>0 = On 1 = Auto 2 = Smart</td> <td>0 = On</td> </tr> <tr> <td>fan control</td> <td>0 = Off 1 = On</td> <td>1 = On</td> </tr> <tr> <td>fan delay</td> <td>0 = Off 1 = On</td> <td>0 = Off</td> </tr> <tr> <td>keypad lockout</td> <td>0 = No_Lockout 1 = Level_1 2 = Level_2</td> <td>No_Lockout</td> </tr> <tr> <td>proportional band</td> <td>2 to 8 F</td> <td>2 F</td> </tr> <tr> <td>temperature units</td> <td>0 = °C 1 = °F</td> <td>°F</td> </tr> <tr> <td>frost protection</td> <td>0 = Off 1 = On</td> <td>0 = Off</td> </tr> <tr> <td>temperature scale</td> <td>0 = °C 1 = °F</td> <td>°F</td> </tr> </tbody> </table>	Name	Valid Range	Default value	password	0 to 1000	0	unoccupied timer	0.5 to 24.0 hours	0.5	anticycle	0, 1, 2, 3, 4, or 5 minutes	2 minutes	power-up delay	10 to 120 sec.	10 sec.	temporary occ time	0, 1, 2, 3 to 12 hours	3 hours	heating stages cph	3, 4, 5, 6, 7 or 8 CPH	4 CPH	cooling stages cph	3 or 4 CPH	4 CPH	heat maximum setpoint	40 to 90°F (4.5 to 32°C)	90°F	cool minimum setpoint	54 to 100°F (12 to 37.5°C)	54°F	oa temp heat lockout	-15 to 120°F (-26 to 49°C)	120°F	oa temp cool lockout	-40 to 95°F (-40 to 35°C)	-40°F	calib room sensor	±5°F (±2.5°C)	0°F	calib outdoor air sensor	±5°F (±2.5°C)	0°F	deadband	2 to 4°F with 1°F increments (1 to 2°C)	2°F	fan mode	0 = On 1 = Auto 2 = Smart	0 = On	fan control	0 = Off 1 = On	1 = On	fan delay	0 = Off 1 = On	0 = Off	keypad lockout	0 = No_Lockout 1 = Level_1 2 = Level_2	No_Lockout	proportional band	2 to 8 F	2 F	temperature units	0 = °C 1 = °F	°F	frost protection	0 = Off 1 = On	0 = Off	temperature scale	0 = °C 1 = °F	°F
		Name	Valid Range	Default value																																																																			
		password	0 to 1000	0																																																																			
		unoccupied timer	0.5 to 24.0 hours	0.5																																																																			
		anticycle	0, 1, 2, 3, 4, or 5 minutes	2 minutes																																																																			
		power-up delay	10 to 120 sec.	10 sec.																																																																			
		temporary occ time	0, 1, 2, 3 to 12 hours	3 hours																																																																			
		heating stages cph	3, 4, 5, 6, 7 or 8 CPH	4 CPH																																																																			
		cooling stages cph	3 or 4 CPH	4 CPH																																																																			
		heat maximum setpoint	40 to 90°F (4.5 to 32°C)	90°F																																																																			
		cool minimum setpoint	54 to 100°F (12 to 37.5°C)	54°F																																																																			
		oa temp heat lockout	-15 to 120°F (-26 to 49°C)	120°F																																																																			
		oa temp cool lockout	-40 to 95°F (-40 to 35°C)	-40°F																																																																			
		calib room sensor	±5°F (±2.5°C)	0°F																																																																			
		calib outdoor air sensor	±5°F (±2.5°C)	0°F																																																																			
		deadband	2 to 4°F with 1°F increments (1 to 2°C)	2°F																																																																			
		fan mode	0 = On 1 = Auto 2 = Smart	0 = On																																																																			
		fan control	0 = Off 1 = On	1 = On																																																																			
		fan delay	0 = Off 1 = On	0 = Off																																																																			
		keypad lockout	0 = No_Lockout 1 = Level_1 2 = Level_2	No_Lockout																																																																			
		proportional band	2 to 8 F	2 F																																																																			
		temperature units	0 = °C 1 = °F	°F																																																																			
frost protection	0 = Off 1 = On	0 = Off																																																																					
temperature scale	0 = °C 1 = °F	°F																																																																					

Parameter	Variable Name	Function		
Thermostat's common configuration parameters network input config	UNVT_cfg_2_rtu_hp <b>nciCfg2RtuHpt</b>	Name	Valid Range	Default value
		di1 config	0 = None 1 = RemNSB 2 = RemOVR 3 = Filter 4 = Service	0 = None
		di2 config	0 = None 1 = RemNSB 2 = RemOVR 3 = Filter 4 = Service	0 = None
		aux contact config	0 = NORMALLY_OPEN 1 = NORMALLY_CLOSE	0
		number of events	2 or 4	2
		progressive recovery	0 = Off 1 = Active	0 = Off
		a.hp rev valve config	1 = Normally Heat 2 = Normally Cool	2
		a.number of heating stages	1 = 1 Stage 2 = 2 Stages	2
		number of cool or hp stages	1 = 1 Stage 2 = 2 Stages	2
		econo min position	0 to 100%	0%
		b.hp high balance point	34 to 90°F (1 to 32°C)	90°F
		b.econo changeover setpoint	14 to 70°F (-10 to 21°C)	55°F
		c.hp low balance point	-40 to 30°F(-40 to -1°C)	-12°F
		c.econo mixed air setpoint	50 to 90°F (10 to 32°C)	50°F
		d.hp comfort or economy mode	0 = Comfort 1 = Economy	0 = Comfort
		d.econo mechanical cool enable	0 = Off 1 = On	0 = Off
		hp compressor auxheat interlock	0 = Off 1 = On	0 = Off
HVAC Unit-Type Identifier	network input config SNVT_hvac_type <b>nciHvacType</b>	<ul style="list-style-type: none"> <li>➤ This configuration property helps the user identify the type of equipment being monitored.</li> <li>➤ Valid Range:</li> </ul>		
		Value	Identifier	Name
		0	HVT_GENERIC – <b>Not Used</b>	Generic
		1	HVT_FAN_COIL	Fan Coil
		2	HVT_VAV – <b>Not Used</b>	Variable Air Volume Terminal
		3	HVT_HEAT_PUMP	Heat Pump
		4	HVT_ROOFTOP	Rooftop Unit
		5	HVT_UNIT_VENT – <b>Not Used</b>	Unit Ventilator
		6	HVT_CHIL_CEIL – <b>Not Used</b>	Chilled Ceiling
		7	HVT_RADIATOR – <b>Not Used</b>	Radiator
8	HVT_AHU – <b>Not Used</b>	Air Handling Unit		
9	HVT_SLF_CONT – <b>Not Used</b>	Self-Contained Unit		

Parameter	Variable Name	Function												
Thermostat's model number	network input config UNVT_model_info_2 <b>nciSccModel</b>	<ul style="list-style-type: none"> <li>➤ This configuration property defines model number and software version of the thermostat</li> <li>➤ Valid Range and Default values:</li> </ul> <table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th>Sub</th> <th>Name</th> <th>Valid Range</th> <th>Default value</th> </tr> </thead> <tbody> <tr> <td>01</td> <td>Thermostat Model</td> <td>11 = VT7600A 12 = VT7600H 10 = VT7600B 09 = VT7605B 02 = VT7652A 06 = VT7652B 01 = VT7656B 04 = VT7652H</td> <td>Depend on model being used</td> </tr> <tr> <td>02</td> <td>Software Version</td> <td>Unsigned short</td> <td>Thermostat dependent</td> </tr> </tbody> </table>	Sub	Name	Valid Range	Default value	01	Thermostat Model	11 = VT7600A 12 = VT7600H 10 = VT7600B 09 = VT7605B 02 = VT7652A 06 = VT7652B 01 = VT7656B 04 = VT7652H	Depend on model being used	02	Software Version	Unsigned short	Thermostat dependent
Sub	Name	Valid Range	Default value											
01	Thermostat Model	11 = VT7600A 12 = VT7600H 10 = VT7600B 09 = VT7605B 02 = VT7652A 06 = VT7652B 01 = VT7656B 04 = VT7652H	Depend on model being used											
02	Software Version	Unsigned short	Thermostat dependent											
Maximum Send Time	network input config SNVT_time_sec <b>nciSendHrtBt</b>	<ul style="list-style-type: none"> <li>➤ This configuration property defines the maximum period of time that expires before the specified network variable outputs will automatically be updated</li> <li>➤ Valid Range: 0 sec. To 6553.4 sec.. Setting nciSendHrtBt to 0 disables the Send Heartbeat mechanism.</li> <li>➤ Default Null Value : 0.0 sec (no automatic update)</li> </ul>												
Minimum Send Time	network input config SNVT_time_sec <b>nciMinOutTm</b>	<ul style="list-style-type: none"> <li>➤ This configuration property defines the minimum period of time between automatic network variable outputs transmissions.</li> <li>➤ Valid Range: 0 sec. to 6553.4 sec.. Setting nciRcvHrtBt to 0 disables the Minimum Send Time mechanism.</li> <li>➤ Default Null Value : 0.0 sec (no minimum send time)</li> </ul>												
Minimum Receive Time	network input config SNVT_time_sec <b>nciRcvHrtBt</b>	<ul style="list-style-type: none"> <li>➤ This configuration property is used to control the maximum time that elapses after the last update to a specified network variable input before the Space Comfort Controller starts to use its default values.</li> <li>➤ Valid Range: 0 sec. to 6553.4 sec.. Setting nciRcvHrtBt to 0 disables the Receive Heartbeat mechanism.</li> <li>➤ Default Null Value : 0.0 sec (no failure detected)</li> </ul>												
Hardware or Software revisions	network input config SCPT_maj_ver <b>nciMajVer</b>	<ul style="list-style-type: none"> <li>➤ This configuration property defines the major module software revisions.</li> <li>➤ Valid Range: 0 to 255</li> </ul>												
Hardware or Software revisions	network input config SCPT_min_ver <b>nciMinVer</b>	<ul style="list-style-type: none"> <li>➤ This configuration property defines the minor module software revisions.</li> <li>➤ Valid Range: 0 to 255</li> </ul>												
Location Label	network input config SNVT_str_asc <b>nciLocation</b>	<ul style="list-style-type: none"> <li>➤ This configuration property can optionally be used to provide more descriptive physical location information than can be provided by the Neuron Chip's 6 byte location string. The location relates to the object and not to the node.</li> <li>➤ Valid Range: Any NULL terminated ASCII string of 31 bytes total length</li> </ul>												

## Integration – Global Commands

The following figure shows which objects from the thermostat can be monitored and commanded from the BAS front-end.




Figure 1: Global commands from a BAS front-end to a VT7600 series tstat

## Integration – Graphic User Interface (GUI) Objects

The following objects should be typically used in a GUI:

- nvoSpaceTemp
- occupied\_heat (nciSetpts);
- unoccupied\_heat (nciSetpts);
- occupied\_cool (nciSetpts);
- unoccupied\_cool (nciSetpts);
- nvoOutdoorTemp
- nvoDischAirTemp
- nvoEffectOccup
- heat\_output\_primary (nvoUnitStatus)
- cool\_output (nvoUnitStatus)
- fan (nvoSccStatus)
- cool\_1 (nvoSccStatus)
- cool\_2 (nvoSccStatus)
- heat\_1 (nvoSccStatus)
- heat\_2 (nvoSccStatus)
- service\_alarm (nvoSccStatus)
- filter\_alarm (nvoSccStatus)
- d2\_direct (nvoSccStatus)
- d1\_direct (nvoSccStatus)
- frostpro\_alarm (nvoSccStatus)
- econ\_output (nvoUnitStatus)




Figure 2: Graphical User Interface (GUI) example of a Roof Top Unit



## Configuration Objects

---

The following SNVT and UNVT should be typically used for configuration purposes:

- nciCfg1RtuHp;
- nciSetpoints;
- nciCfg2RtuHp;
- nviDaySchedule[0]
- nviDaySchedule[1]
- nviDaySchedule[2]
- nviDaySchedule[3]
- nviDaySchedule[4]
- nviDaySchedule[5]
- nviDaySchedule[6]

## Wiring Guide

---

### Overview

For clarity we will use the term “Device” to represent any product with an active Echelon network connection, including Vykon and non-Vykon controllers.

### Summary Specifications:

Parameter	Details
Network Wiring	24 to 16AWG, twisted pair
Maximum total wire length <sup>1</sup>	1600 feet (500 meters) in free topology
Maximum device-to-device distance	1600 feet (500 meters) in free topology
Polarity	Polarity insensitive
Multi-drop	Free Topology
Termination for Free Topology Network Segment	One RC network with $R_a = 52.3\Omega \pm 1\%$ , 1/8W
Termination for Doubly Terminated Bus Network Segment	Two RC network with $R_a = 105\Omega \pm 1\%$ , 1/8W
Number of transceivers per segment	Up to 64
Baud rate	78000 bits per second

<sup>1</sup>Network segment length varies depending on wire type.

Table 1: Summary of Specifications for a Vykon' EIA-485 Network

## Network Configuration

---

The Echelon network is designed to support free topology wiring and will accommodate bus, star, loop or any of these topologies. Echelon devices can be located at any point along the network wiring.

Figures 3.1 to 3.5 present five different network topologies. The actual termination circuit will vary by application.



Figure 3.1 Singly Terminated Bus Topology



Figure 3.2 Doubly Terminated Bus Topology



Figure 3.3 Star Topology




Figure 3.4 Loop Topology




Figure 3.5 Mixed Topology

### Maximum Number Of Devices

Up to 64 transceivers are allowed per network segment. If your network requires more than 64 transceivers a repeater is then required to extend your network

## Maximum Cable Length

The maximum length of a chain is related to its transmission speed. Using proper cable, Echelon supports a baud rate of 78 kilobits per second for distances up to 1600-ft (500 m) in free topology and 8800 ft (2700 m) in bus topology with double terminations.

If you require a maximum network length of more than 1600-ft (500 m) or 8800 ft (2700 m), then a repeater is required to extend the network.

## Repeater

In the event that the limits on the number of transceivers or total wire distance are exceeded, a physical layer repeater can be added to interconnect two or more network segments. A repeater will double the overall channel capability, including node count and network extent, but not bandwidth. Note that only one physical layer repeater should be placed in series between any two nodes on a channel. If additional cabling or network bandwidth is required, then a LonWorks Router should be used in place of a repeater.

## Terminators

Echelon network segments requires termination for proper data transmission performance. The type of terminator varies depending on whether shielded or unshielded cable is used. Free topology and Bus networks also differ in their termination requirements. The following sections describe the various terminators and terminations procedure.

### Free Topology Network Segment

In a free topology segment, only one termination is required and may be placed anywhere on the free topology segment. There are two choices for the termination:

1. RC network with  $R_a = 52\Omega \pm 1\%$ , 1/8W
2. LPI-10 Link Power Interface, with jumper at "1 CPLR" setting.

### Doubly Terminated Network Segment

In a doubly terminated bus topology, two terminations are required, one at each end of the bus. There are two choices for each termination:

1. RC network with  $R_a = 105\Omega \pm 1\%$ , 1/8W
2. LPI-10 Link Power Interface, with jumper at "2 CPLR" setting.

Only one LPI-10 interface is supported per segment. The other terminator must be an RC-type.

### Grounding Shielded Twisted Pair Cable

When using Shielded Twisted Pair, terminate the twisted pair as listed in the previous section and ground the cable shield by using a capacitor, to tie the shield to earth ground, and a large-value resistor to bleed off any static charge on the shield. Tying the shield to earth ground through a capacitor will avoid DC and 50/60Hz ground paths from being formed through the shield. Typical values for resistor and capacitor are as follows:

Capacitor = 0.1 $\mu$ F, 10%, Metalized Polyester,  $\geq 100V$

Resistor = 470k $\Omega$ , 1/4W,  $\pm 5\%$

The cable shield should be grounded at least once per segment, and preferably at each node. Grounding the shield at every node will assist in suppressing 50/60Hz standing waves.

## Network Adapter

Although network connections are polarity insensitive, it is good practice to keep polarity consistent throughout the entire site. Figure 4 shows a network connection example and the location of the Status LED. This Status LED may help to troubleshoot network problems.




Figure 4: Network connections and location of the Status LED on a LON module

Table 2 shows the different possibilities with the Status LED behavior of the LON module.

Condition of the Status LED	Explanation
➤ Continuously ON	The Echelon communication module has no valid application loaded in its memory.
➤ Flashing at a rate of 1/2Hz	The Echelon communication module has an application loaded in its memory but is Unconfigured. When an Echelon communication module is in the unconfigured state, the application is not running. This is the default state when the devices are shipped. A network management tool should be used to configure the module and integrate the device to a LonWorks network.
➤ Continuously OFF	The Echelon communication module has an application loaded into its memory and the application is running.

Table 2: Status LED condition

## Software Files

**XIF:** When binding a node onto the network, an XIF file is needed. The XIF file has information that is used by the network management tool to help ease the installation and maintenance process of a node. It is also used for offline configuration of the node.

**APB and NXE:** When running an application program associated with a XIF file, an APB or NXE file is needed. Please note that the thermostats have the APB file already flashed from the factory.

**Device Resource File (DRF):** When a LON network management tool is used; a DRF file must be installed. DRF files are needed to display special manufacturer defined variables or configurations correctly.

- Please note that all release notes for the XIF, APB & NXE software files will be included under the following folder name on your hard drive: C:\LonWorks\Import\Vykon. The name of the file is: VT7xxxReadme.txt

**Plug-Ins File:** Plug-Ins simplify start-up, maintenance, configuration and reduce the installation effort.

- Please note that all release notes for Plug-Ins files will be included under the following folder name on your hard drive: C:\LonWorks\Plug-Ins\Vykon\VT7xxx. The name of the file is: Readme.txt.
- All the latest software files can be downloaded from VYKON' web site at <http://www.Niagara-Central.com>

## Device Identification

---

An Echelon device has a unique mechanism to identify itself, the Neuron ID, which is obtained during commissioning.

There are two ways of getting the Neuron ID: with a Service Pin or manually.

### Service PIN

The Service PIN is used to identify the device at commissioning. By pressing simultaneously the “Yes” button and the “No” button located on the keypad interface of a VT7600 device, the program ID and the Neuron ID (LonWorks Unique ID) contained in the device are transmitted to the commissioning or service tool. The Status LED will blink when the device accepts the Service PIN command.

Figures 6 and 7 show an example of a Service PIN request made through a commissioning tool

The screenshot shows a software window titled "Add device" with a blue header bar. Inside, there are three main sections. The first is "New Device Name" with a text input field containing "Device1". The second is "Device Identification Method" with a dropdown menu set to "Service Pin" and a "Get" button next to a "Neuron ID:" label and an empty text box. The third section contains three sub-sections: "Commission" with a checked checkbox for "Commission Device", "Location" with an empty text box, and "Ping Interval" with a dropdown menu set to "2 minutes". A red instruction reads "Click 'Get' button to begin ServicePin method." At the bottom of the window are three buttons: "< Back", "Finish", and "Cancel".

Figure 6: Service Pin request through a commissioning tool

The screenshot shows a software window titled "Press Service Pin" with a blue header bar. The main area contains the text "Press the Service Pin on the device you wish to install!" in blue. A "Cancel" button is located at the bottom right of the window.

Figure 7: Service Pin request through a commissioning tool

## Manual Identification

Neuron ID of a device can also be entered manually through a commissioning or service tool. Neuron ID should be located on the Echelon chip of the device being commissioned.

Figure 8 shows an example of a Manual Neuron ID request made through a commissioning tool.




Figure 8: Manual Neuron ID request

## Tips And Things You Need To Know

---

- In order to operate nviAuxOut (auxiliary output) from the network, Aux contact configuration (Auxcont nciGenOpt) needs to be set as “NetworkControlled”;
- If the heartbeat is lost, the module will release the network sensor value for the Room Temperature (nviSpaceTemp) and the Outdoor Temperature (nviOutdoorTemp);
- The heartbeat parameter of a Vykron front-end should be set at the slowest configuration possible so that nviTimeStamp updates correctly;
- With any LNS Tools, nviTimeStamp should be set to refresh everyday or on power-up;
- For nciMultOpt, Vykron strongly recommend to use either one of the following format file:
  - UNVT\_rt\_opts#US or UNVT\_rt\_opts#SI for Roof Top models
  - UNVT\_hp\_opts#US or UNVT\_hp\_opts#SI for Heat Pump models

## Troubleshooting Section

---

Error / Trouble Condition	Possible Cause	Solution
<b>Thermostat does not come online</b>	The LON network has too many devices.	Do not exceed the maximum number of devices and maximum length allowed by the EIA-485 specifications.
	Too many devices were installed without any repeaters.	Repeaters need to be installed as specified in this document.
	The LON cable runs are broken	Locate the break and correct wiring
	The thermostat does not have power	Apply power to the thermostat